



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

September 6, 2011

RECTORSEAL CORP.
MELISSA SCHOENBERG
2601 SPENWICK DR.
HOUSTON TX 77055

Re: Description: SOLVENT CEMENT
Manufacturer: RECTORSEAL CORP.
Product Name: RECTORSEAL ARCTIC 616L
Model Number(s): 55900, 55909, 55919, 55948 & 55953
Product File No: 20110281

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.40 (14)(b) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be used on PVC gravity flow DWV pipe without primer.

This approval supersedes the approval issued on March 29, 2006 under product file number 20060074.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060074.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov